

Act/Prnt State	ActchvTime	Condition	Message	Class	ObjectDescription
3 ACT	16 03 16 07:00:23:49	FAL_6132	Less than 359.0 kg/hr	1	Make-up Water Flow
2 ACT	16 03 16 07:00:23:49	FAL_6132	Less than 359.0 kg/hr	1	Make-up Water Flow
2 ACT	16 03 16 06:01:48:48	LAL_6262	Less than 22.2 pct	1	Chemical LP Level Tank1
2 ACT	16 03 16 06:01:48:48	LAL_6262	Less than 22.2 pct	1	Chemical LP Level Tank1
2 ACT	16 03 16 06:01:48:48	LAL_6262	Less than 22.2 pct	1	Chemical LP Level Tank1
2 RTN	16 03 16 06:01:46:58	LAL_6262	Less than 22.2 pct	1	Chemical LP Level Tank1
2 RTN	16 03 16 06:00:34:58	LAL_6262	Less than 22.2 pct	1	Chemical LP Level Tank1
2 RTN	16 03 16 06:00:34:58	LAL_6262	Less than 22.2 pct	1	Chemical LP Level Tank1
2 RTN	16 03 16 03:32:35:54	Inoperative	Service Provider in Operational State	0	Chemical LP Level Tank1
1 ACT	16 03 16 03:32:35:54	Inoperative	Service Provider not in Operational State	0	Chemical LP Level Tank1
1 ACT	16 03 16 03:32:31:26	OPCServerStopped	OPC DA server stopped. Supervision timeout	0	Chemical LP Level Tank1
1 RTN	16 03 16 03:32:31:26	OPCServerStopped	OPC DA server stopped. Supervision timeout	0	Chemical LP Level Tank1
2 RTN	15 03 16 23:56:00:98	Inoperative	Service Provider in Operational State	0	Chemical LP Level Tank1
2 ACT	15 03 16 23:56:00:98	Inoperative	Service Provider not in Operational State	0	Chemical LP Level Tank1
1 RTN	15 03 16 23:55:54:80	OPCServerStopped	OPC DA server stopped. Supervision timeout	0	Chemical LP Level Tank1
1 RTN	15 03 16 23:55:54:80	OPCServerStopped	OPC DA server stopped. Supervision timeout	0	Chemical LP Level Tank1
2 RTN	15 03 16 18:32:46:50	Inoperative	Service Provider in Operational State	0	Chemical LP Level Tank1
2 ACT	15 03 16 18:32:46:50	Inoperative	Service Provider not in Operational State	0	Chemical LP Level Tank1
1 ACT	15 03 16 18:32:40:92	OPCServerStopped	OPC DA server stopped. Supervision timeout	0	Chemical LP Level Tank1
1 RTN	15 03 16 18:32:40:92	OPCServerStopped	OPC DA server stopped. Supervision timeout	0	Chemical LP Level Tank1
2 RTN	15 03 16 17:54:39:33	PAL_6328	Less than 1.5 barg	1	Make-up Water Pressure
2 ACT	15 03 16 17:54:39:33	PAL_6328	Less than 1.5 barg	1	Make-up Water Pressure
2 RTN	15 03 16 17:54:36:83	PAL_6328	Less than 1.5 barg	1	Make-up Water Pressure
2 ACT	15 03 16 17:54:36:83	PAL_6328	Less than 1.5 barg	1	Make-up Water Pressure
2 RTN	15 03 16 17:32:19:57	Inoperative	Service Provider in Operational State	0	Make-up Water Pressure
2 ACT	15 03 16 17:32:19:57	Inoperative	Service Provider not in Operational State	0	Make-up Water Pressure
1 ACT	15 03 16 17:32:13:34	OPCServerStopped	OPC DA server stopped. Supervision timeout	0	Make-up Water Pressure
1 RTN	15 03 16 17:32:13:34	OPCServerStopped	OPC DA server stopped. Supervision timeout	0	Make-up Water Pressure
3 RTN	15 03 16 16:54:07:42	FAL_6132	Less than 359.0 kg/hr	1	Make-up Water Flow
2 RTN	15 03 16 16:54:07:42	FAL_6132	Less than 359.0 kg/hr	1	Make-up Water Flow
3 ACT	15 03 16 16:54:07:42	FAL_6132	Less than 359.0 kg/hr	1	Make-up Water Flow
2 ACT	15 03 16 16:54:07:42	FAL_6132	Less than 359.0 kg/hr	1	Make-up Water Flow
3 RTN	15 03 16 16:53:58:32	FAL_6132	Less than 359.0 kg/hr	1	Make-up Water Flow
3 ACT	15 03 16 16:53:58:32	FAL_6132	Less than 359.0 kg/hr	1	Make-up Water Flow
2 ACT	15 03 16 16:53:58:32	FAL_6132	Less than 359.0 kg/hr	1	Make-up Water Flow
2 ABT	15 03 16 16:47:46:81	PAL_6328	Less than 1.5 barg	1	Make-up Water Pressure
2 ACT	15 03 16 16:47:46:81	PAL_6328	Less than 1.5 barg	1	Make-up Water Pressure
2 RTN	15 03 16 16:47:41:31	PAL_6328	Less than 1.5 barg	1	Make-up Water Pressure
2 ACT	15 03 16 16:47:41:31	PAL_6328	Less than 1.5 barg	1	Make-up Water Pressure
2 RTN	15 03 16 16:47:39:81	PAL_6328	Less than 1.5 barg	1	Make-up Water Pressure
2 ACT	15 03 16 16:47:39:81	PAL_6328	Less than 1.5 barg	1	Make-up Water Pressure
2 RTN	15 03 16 16:46:59:31	PAL_6328	Less than 1.5 barg	1	Make-up Water Pressure
2 ACT	15 03 16 16:46:59:31	PAL_6328	Less than 1.5 barg	1	Make-up Water Pressure
2 RTN	15 03 16 16:32:32:24	Inoperative	Service Provider in Operational State	0	Make-up Water Pressure
2 ACT	15 03 16 16:32:32:24	Inoperative	Service Provider not in Operational State	0	Make-up Water Pressure
1 ACT	15 03 16 16:32:25:28	OPCServerStopped	OPC DA server stopped. Supervision timeout	0	Make-up Water Pressure
1 RTN	15 03 16 16:32:25:28	OPCServerStopped	OPC DA server stopped. Supervision timeout	0	Make-up Water Pressure
2 RTN	15 03 16 16:14:17:77	PAL_6328	Less than 1.5 barg	1	Make-up Water Pressure